

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE
 (REQUIREMENTS FOR ELECTRICAL INSTALLATIONS - BS 7671 [IET WIRING REGULATIONS])
 To be used only for minor electrical work which does not include the provision of a new circuit

PART 1: Description of the minor works	
1. Details of the Client	Date minor works completed
2. Installation location/address	
3. Description of the minor works	
4. Details of departures, if any, from BS 7671:2018 for the circuit altered or extended (Regulation 120.3, 133.1.3 and 133.5): Where applicable, a suitable risk assessment(s) must be attached to the Certificate	
Risk assessment attached <input type="checkbox"/>	
5. Comments on (including any defects observed in) the existing installation (Regulation 644.1.2):	
PART 2: Presence and adequacy of installation earthing and bonding arrangements (Regulation 132.16)	
1. System earthing arrangement: TN-S <input type="checkbox"/> TN-C-S <input type="checkbox"/> TT <input type="checkbox"/>	
2. Earth fault loop impedance at distribution board (Z_{db}) supplying the final circuit Ω	
3. Presence of adequate main protective conductors:	
Earthing conductor <input type="checkbox"/>	
Main protective bonding conductor(s) to: Water <input type="checkbox"/> Gas <input type="checkbox"/> Oil <input type="checkbox"/> Structural steel <input type="checkbox"/> Other..... <input type="checkbox"/>	
PART 3: Circuit details	
DB Reference No.: DB Location and type:	
Circuit No.: Circuit description:	
Circuit overcurrent protective device:	BS(EN) Type Rating A
Conductor sizes:	Live mm ² cpc mm ²
PART 4: Test results for the circuit altered or extended (where relevant and practicable)	
Protective conductor continuity:	$R_1 + R_2$ Ω or R_2 Ω
Continuity of ring final circuit conductors:	L/L Ω N/N Ω cpc/cpc Ω
Insulation resistance:	Live - Live M Ω Live - Earth M Ω
Polarity satisfactory: <input type="checkbox"/>	Maximum measured earth fault loop impedance: Z_s Ω
RCD operation: Rated residual operating current ($I_{\Delta n}$) mA	
Disconnection time ms	
Satisfactory test button operation <input type="checkbox"/>	
PART 5: Declaration	
I certify that the work covered by this certificate does not impair the safety of the existing installation and the work has been designed, constructed, inspected and tested in accordance with BS 7671:2018 (IET Wiring Regulations) amended to (date) and that to the best of my knowledge and belief, at the time of my inspection, complied with BS 7671 except as detailed in Part 1 above.	
Name:	Signature:
For and on behalf of:	Position:
Address:	Date:
.....
.....